

AlarmSense

Optical Smoke Detectors



Product overview	
Product	Optical Smoke Detector
Part No.	55000-390
Product	Integrating Optical Smoke Detector
Part No.	55000-391

Compliance





Product information



Caution: System compatibility

AlarmSense detectors can only be used in a system that is powered and controlled by purpose designed AlarmSense fire control panels*.

The AlarmSense Optical Smoke Detectors work using the light scatter principle. The optical detector changes to alarm state at a pre-set threshold of smoke penetration into the sensing chamber. The integrating optical detector has the ability to monitor and discard transient sources of smoke, and has a 20 second delay before changing into an alarm state.

- · Responds well to slow-burning, smouldering fires
- · Suitable for bedrooms and escape routes
- · 360° visibility of LEDs
- · Reduces false alarms
- · Quick and simple installation

Technical data

All data is supplied subject to change without notice. Specifications are typical at 24 V, 25°C and 50% RH unless otherwise stated.

Detection principle Photo-electric detection of light

scattered by smoke particles over a

wide range of angles.

Sampling frequency Once every four seconds

Supply voltage 9 V dc - 33 V dc

Supply wiring Two wire supply, polarity insensitive

Quiescent current at 15 V $< 50 \mu A$

Alarm current at

2 - 8.5 V < 1.5 mA 10.5 - 15 V 25 ± 2 mA 18 - 24 V < 1.5 mA 33 V < 2 mA

Maximum reset voltage2 VReset time1 secMax supply interruption time40 ms

Operatng temperature $-10 \, ^{\circ}\text{C}$ to $+55 \, ^{\circ}\text{C}$ Humidity0% to 93% RH

(no condensation or icing)

IP Rating designed to IP44
Standards and approvals EN 54-7, CPR, FG

Dimensions 100 mm diameter x 42 mm height

100 mm diameter x 50 mm height

in base

Weight 90 g detector

Materials Housing: White flame-retardant

polycarbonate

Terminals: Nickel plated stainless

steel

EMC Directive 2014/30/EU

The AlarmSense Optical Smoke Detectors comply with the essential requirements of the EMC Directive 2014/30/EU, provided that they are used as described in this data sheet.

A copy of the Declaration of Conformity is available from Apollo upon request.

Conformity of the AlarmSense Optical Smoke Detectors with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to it.

Construction Products Regulation 305/2011/EU

The AlarmSense Optical Smoke Detectors comply with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from Apollo upon request.

36 Brookside Road, Havant Hampshire, PO9 1JR, UK. Tel: +44 (0)23 9249 2412 Fax: +44 (0)23 9249 2754

Email: sales@apollo-fire.com Web: www.apollo-fire.co.uk All information in this document is given in good faith but Apollo Fire Detectors Ltd cannot be held responsible for any omissions or errors. The company reserves the right to change the specifications of products at any time and without prior notice.









^{*} For further information on suitable fire control panels please contact Apollo Technical Sales: techsales@apollo-fire.com



This page has intentionally been left blank

